



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 12/24/09

Code 52.3.6.1-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

| | | |
|---|---|--------------------------|
| Code Title 2009 Indiana Residential Code | | Edition First Edition |
| Section number and title N1102.1.2, Table | | Page 1 of 1 |
| Proponent Craig Wagner | Title Chief Building Inspector/ IABO Code Comm. Member | |
| Address 220 W Van Buren St, Columbia City IN 46725 | | Phone 260-248-3111 |
| PROPOSED CODE CHANGE (Check One) | | |
| <input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution | | |
| <p>Change footnote b. in code proposal 52.3.6 as follows:</p> <p>b. When more than half the insulation is on the interior, the mass wall U-factors shall be a maximum 3-0 <u>0.10</u> in Zone 4, and the same factor <u>as the frame wall U-factor (0.057)</u> in Zone 5.</p> | | |
| REASON | | |
| <p>This change changes the text of the previous proposal to be the same as the text in the 2009 IECC.</p> <p>Fiscal impact: no increase to the cost of construction.</p> | | |
| REVIEW RECOMMENDATION | | |
| Approve | | |
| Disapprove | | |
| Approve as amended | | |
| Further Study | | |